








# Lighting Energy Saving Report

## Typical School



Survey Conducted By: Nick

	Existing Lighting System	Energy Efficient Lighting System	Savings
Annual Energy Consumption kWh	40,341	14,612	25,729
CO2 Emissions (tonnes)	9.40	3.40	5.99
Maintenance (£)	950	0	950
Estimated Annual Running Cost (£)	11,883	4,304	7,579



Figures based on Inflation Rate of 3 %, and base electricity cost of £0.265 kWh